



LDAR Report

Enbridge

Accident Storage Compressor Station

Quarterly Report

COMAR 26.11.41

PERIOD: Q2 2023

Prepared By:

Montrose Air Quality Services, LLC

412 Darby Way (Suite 2)

Bridgeville, Pennsylvania 15017

www.montrose-env.com

Report Generated on: 8/1/2023

Company:	Enbridge	Report:	Quarterly LDAR		
District:	Storage-North	Regulation(s):	COMAR 26.11.41		
Facility Name:	Accident Storage Compressor Station	Report Date:	2023-Aug-01		
		Period:	2023-Apr-01	TO	2023-Jun-30

This report satisfies the requirements of COMAR 26.11.41 for the collection of fugitive emissions components at the above referenced compressor station.

Information required to be reported per §26.11.41 07 A.(1)(a)

Monitoring Quarter	Q2	N/A	N/A	N/A	N/A
Survey Start Date/Time	6/12/2023 8:30				
Survey End Date/Time	6/12/2023 17:00				
LDAR Instrument	Optical Gas Imaging/GFX-320				
§26.11.41 07 A.(1)(a)(iii) Deviations from Monitoring Plan	No deviations from the Monitoring Plan				
Deviation(s) Explanation	N/A				

§26.11.41 07 A.(1)(a)(iv) - Number and type of components for which fugitive emissions were detected

Valves	16				
Connectors	11				
Pressure Relief Devices					
Open-Ended Lines					
Flanges	9				
Compressors	3				
Instruments	5				
Meters					
Other					
Total No. of Leaks Detected	44				

§26.11.41 07 A.(1)(a)(vii) - Number and type of components that were tagged as a result of not being repaired during the monitoring survey

Valves	4				
Connectors	3				
Pressure Relief Devices					
Open-Ended Lines					
Flanges	8				
Compressors	3				
Instruments	2				
Meters					
Other					

§26.11.41 07 A.(1)(a)(v) - Number and type of difficult-to-monitor and unsafe-to-monitor fugitive emission components monitored

Valves					
Connectors					
Pressure Relief Devices					
Open-Ended Lines					
Flanges					
Compressors					
Instruments					
Meters					
Other					

§26.11.41 07 A.(1)(a)(ix) - Date of successful repair of the fugitive emission component (see Repair List).

§26.11.41 07 A.(1)(a)(viii) - Number and type of fugitive emission components placed on delay of repair and explanation for each delay of repair (see DOR List).

§26.11.41 07 A.(1)(a)(x) - Type of instrument used to resurvey a repaired fugitive emissions component that could not be repaired during the initial fugitive emissions finding (see Repair List).



Fugitive Emissions Components Placed on DOR				
This summary satisfies the annual reporting requirements of §26.11.41 07 A.(1)(a)(viii), "number and type of fugitive emission components placed on delay of repair and explanation for each delay of repair".				
Component				
Quarter	Q2	N/A	N/A	N/A
Survey Date	6/12/2023			
Valves	3			
Connectors	2			
Pressure Relief Devices				
Open-Ended Lines				
Flanges	8			
Compressors	3			
Instruments	2			
Meters				
Other				
Total No. of Leaks placed on DOR	18			
Date Surveyed	Emission ID #	Component Type	Current Repair Status	Delay of Repair Explanation / Justification
06/12/2023	35625317	Connector	Delay of Repair	Shutdown Required
06/12/2023	35625318	Flange	Delay of Repair	Shutdown Required
06/12/2023	35625319	Connector	Delay of Repair	Shutdown Required
06/12/2023	35625324	Flange	Delay of Repair	Shutdown Required
06/12/2023	35625325	Instrument	Delay of Repair	Shutdown Required
06/12/2023	35625328	Flange	Delay of Repair	Shutdown Required
06/12/2023	35625329	Flange	Delay of Repair	Shutdown Required
06/12/2023	35625332	Flange	Delay of Repair	Shutdown Required
06/12/2023	35625334	Instrument	Delay of Repair	Shutdown Required
06/12/2023	35625335	Compressor	Delay of Repair	Shutdown Required
06/12/2023	35625337	Flange	Delay of Repair	Shutdown Required
06/12/2023	35625340	Compressor	Delay of Repair	Shutdown Required
06/12/2023	35625341	Flange	Delay of Repair	Shutdown Required
06/12/2023	35625343	Compressor	Delay of Repair	Shutdown Required
06/12/2023	35625344	Flange	Delay of Repair	Shutdown Required
06/12/2023	35625351	Valve	Delay of Repair	Shutdown Required
06/12/2023	35625352	Valve	Delay of Repair	Shutdown Required
06/12/2023	35625355	Valve	Delay of Repair	Shutdown Required
11/14/2022	92510155	Connector	Delay of Repair	Shutdown required
11/14/2022	92510159	Valve	Delay of Repair	Shutdown required
11/14/2022	92510160	Valve	Delay of Repair	Shutdown required

Fugitive Emissions Components Repaired During Reporting Period

This summary satisfies the annual reporting requirements of §26.11.41 07 A.(1)(a)(ix), "date of successful repair of the fugitive emission component" and §26.11.41 07 A.(1)(a)(x), "type of instrument used to resurvey a repaired fugitive emissions component that could not be repaired during the initial fugitive emissions finding".

Date Surveyed	Emission ID #	Date of Successful Repair	Repair Confirmation Method / Instrument
03/06/2023	32625519	4/17/2023	Bubble Test
03/06/2023	32625523	4/17/2023	Bubble Test
03/06/2023	32625525	4/17/2023	Bubble Test
03/06/2023	32625526	4/17/2023	Bubble Test
03/06/2023	32625531	4/26/2023	Bubble Test
06/12/2023	35625320	6/15/2023	OGI
06/12/2023	35625321	6/13/2023	OGI
06/12/2023	35625322	6/13/2023	OGI
06/12/2023	35625323	6/13/2023	OGI
06/12/2023	35625326	6/15/2023	OGI
06/12/2023	35625327	6/15/2023	OGI
06/12/2023	35625330	6/13/2023	OGI
06/12/2023	35625331	6/13/2023	OGI
06/12/2023	35625333	6/15/2023	OGI
06/12/2023	35625336	6/15/2023	OGI
06/12/2023	35625338	6/15/2023	OGI
06/12/2023	35625339	6/15/2023	OGI
06/12/2023	35625342	6/13/2023	OGI
06/12/2023	35625345	6/15/2023	OGI
06/12/2023	35625346	6/29/2023	Bubble Test
06/12/2023	35625347	6/29/2023	Bubble Test
06/12/2023	35625348	6/14/2023	OGI
06/12/2023	35625349	6/14/2023	OGI
06/12/2023	35625350	6/14/2023	OGI
06/12/2023	35625353	6/15/2023	OGI
06/12/2023	35625354	6/15/2023	OGI
06/12/2023	35625356	6/15/2023	OGI
06/12/2023	35625357	6/15/2023	OGI
06/12/2023	35625358	6/15/2023	OGI
06/12/2023	35625359	6/15/2023	OGI
06/12/2023	35625360	6/15/2023	OGI
03/14/2022	88110071	4/27/2023	Bubble Test